

fourth Thursday in November; Christmas Day, December 25. When any of the above-listed holidays falls outside the basic workweek, the nearest workday within that week shall become a holiday.

[40 FR 45800, Oct. 3, 1975, as amended at 43 FR 51754, Nov. 7, 1978; 50 FR 724, Jan. 7, 1985; 50 FR 51513, Dec. 18, 1985; 52 FR 4, Jan. 2, 1987; 53 FR 13397, Apr. 22, 1988; 54 FR 6389, Feb. 10, 1989]

§ 307.6 Basis of billing for overtime and holiday services.

(a) Each recipient of overtime or holiday inspection service, or both, shall be billed as provided for in § 307.5(a) and at the rates specified in § 391.3, in increments of quarter hours. For billing purposes, 8 or more minutes shall be considered a full quarter hour. Billing will be for each quarter hour of service rendered by each Program employee.

(b) Official establishments, importers, or exporters requesting and receiving the services of a Program employee after he has completed his day's assignment and left the premises, or called back to duty during any overtime or holiday period, shall be billed for a minimum of 2 hours overtime or holiday inspection service at the established rate.

(c) Bills are payable upon receipt and become delinquent 30 days from the date of the bill. Overtime or holiday inspection will not be performed for anyone having a delinquent account.

[40 FR 45800, Oct. 3, 1975, as amended at 54 FR 6389, Feb. 10, 1989]

§ 307.7 Safety requirements for electrical stimulating (EST) equipment.

(a) *General.* Electrical stimulating (EST) equipment is equipment that provides electric shock treatment to carcasses for the purpose of accelerating rigor mortis of facilitating blood removal. These provisions do not apply to electrical equipment used to stun and/or slaughter animals or to facilitate hide removal. Electrical stimulating equipment consists of two separate pieces—the control system and the applicator. The EST control system contains the circuitry to generate pulsed DC or AC voltage for stimulation and is separate from the equipment used to apply the voltage to the

carcass. The voltage is applied by inserting a probe that penetrates the carcass or is inserted in the rectum, placing a clamp in the nose, a carcass rubber, a conveyor with energized surfaces traveling with the carcass, or any other acceptable method.

(b) *Safety requirements*—(1) *Circuits, grounding.* Either a bonded grounding conductor shall lead from each section of the carcass rail within the stimulating enclosure to the service ground, or the secondary voltage (stimulating circuit) shall be insulated from the service ground. If the stimulating section of the carcass rail and carcass drive mechanisms are insulated from the service ground then the stimulating rail or the return path shall be electrically bonded to the transformer secondary to isolate the stimulation voltage.

(2) *Enclosure.* Electrical stimulation shall occur in an area that will prevent persons from contacting an energized surface. If the area is surrounded by physical barriers, the enclosure shall be either electrically grounded or it shall be made of materials that do not conduct electricity. The interior of the stimulating area shall be visible from the start switch so the operator can be assured that there is no person, equipment or material present that should not be there prior to starting the stimulating sequence. If light or sound beam sensors form the enclosure, the stimulating equipment shall be automatically shut off when the sensor signals are broken.

(3) *Mandatory Warning Devices and Signals.* The following warning devices or signals shall be installed at each opening to the stimulating area through which a person would normally enter:

(i) A red light that flashes distinctly during the operating cycle of the stimulating equipment.

(ii) An ANSI Z53.1-Color Code sign reading (a) "Danger Electrical Hazard" for stimulating voltage below 50 or (b) "Danger High Voltage" for stimulating voltage above 50.

(iii) An emergency stop button.

(4) *Optional Warning Device—Horn or Bell.* If a warning horn or bell is installed, the signal shall be audible